



State Fire Marshal's Office

PO Box 12107 | Austin, TX 78711 | 512-676-6800 | tdi.texas.gov/fire

6/8/2023

Chief Chris Jackson
436 Skinner Lane
Longview, TX 75306
cjackson@judsonfire.com

Place code: 18316
Community: Judson Metro VFD

Dear Chief Chris Jackson:

Insurance Services Office (ISO) has submitted a recommendation concerning your community's Public Protection Classification (PPC). Currently, the community's Public Protection Classification is a class 06/6X.

Insurance Services Office is recommending the Public Protection Classification be updated as a split class 06/6X, with an effective date of 11/1/2023. The recommendation is based on a review of your community performed on 03/15/2023.

With a split class, all class-rated properties located within 1000 feet of a fire hydrant or water supply suction point and within 5 miles of a fire station will use Class 06. All class-rated properties located farther than 1000 feet of a fire hydrant or water supply suction point and within 5 miles of a fire station will use Class 6X.

Public Protection Classifications range from 1 (superior) to 10 (does not meet minimum criteria).

We have reviewed the information provided and believe it is enough to grant approval. The Insurance Services Office will be notified of our approval of their recommendation and the effective date.

Please make sure all community officials and residents within your district are notified of the new Public Protection Classification rating for your community, and the effective date.

Please share your experience with your Public Protection Classification grading by taking a brief survey at the following link.

[Public Protection Classification Service Feedback Survey \(surveymonkey.com\)](https://surveymonkey.com)

Thank you,



Joel Duke
PPC Oversight Officer
PPCOversight@tdi.texas.gov

TEXAS STATE FIRE MARSHAL

Approved

Disapproved

Signature: Natalie Lynn Robertson Date: _____